

WS Vechtstromen

Enschede

van: naar: product:	Enschede										Enschede														
	Transporteren										Afvoeren														
	Ontvangen										Esbeek														
	Influent										Effluent														
	CZV	BZV5	NKj	Ntot	Ptot	OB	TZV	Q	CZV	BZV5	NKj	NKj	NH4	NO2	NO3	NOx	Ntot	PO4	PO4	Ptot	Ptot	OB	TZV	Q	
	O2	O2	N	N	P	NVT	O2	NVT	O2	O2	N	Nnf	Nnf	N	N	N	N	P	Pnf	P	Pnf	NVT	O2	NVT	
	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	m3 (bem)	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	m3 (bem)		
Gem(rek):*	602	231	51,6	51,6	6,59	230	840	54.374	39,2	2,77	2,83	2,62	0,91	0,22	3,18	3,40	6,22	0,53	0,65	0,88	0,65	3,14	52,1	53.295	
Gem (gew):	541	204	41,8	44,5	5,54	204	750		38,6	3,14	3,20	2,88	1,09	0,23	3,00	3,22	6,22	0,56	0,72	1,01	0,66	4,22	52,4		
Max:	984	448	84,0	84,0	13,6	552	1.354	221.917	52,9	9,60	7,60	6,75	4,99	0,69	4,89	5,19	10,0	2,27	3,79	4,09	2,47	16,6	83,5	221.918	
Min:	171	62,6	9,82	9,82	1,17	57,4	242	26.956	24,6	1,26	1,09	1,17	0,08	0,02	1,72	1,92	3,81	0,05	0,02	0,21	0,06	1,16	30,5	26.956	
StdevP:	206	93,7	17,2	17,2	2,34	101	281	33.600	6,44	1,31	1,26	1,11	1,06	0,17	0,64	0,62	1,23	0,60	0,78	0,84	0,61	3,27	10,5	33.759	
percentiel (95%)	956	400	80,1	80,1	10,5	376	1.335	94.894	47,3	5,27	5,04	4,04	2,78	0,52	4,04	4,39	8,67	1,82	2,56	2,86	1,92	11,9	73,0	112.825	
Aantal:	26	26	59	59	59	26	26	59	63	63	64	26	63	63	63	63	63	22	64	64	26	63	63	64	

WS Vechtstromen

Enschede

van: naar: product:	Enschede Afvoeren Transporteren oppervlaktewater Effluent										
	Cd	Cr	Cu	Pb	Ni	Zn	Hg	As	Al	Q	
	NVT	NVT	NVT	NVT	NVT	NVT	NVT	NVT	NVT		
	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	m3	
	Gem(rek):	0	7,27	9,00	0	13,9	65,5	0	0	0	40.857
	Gem(gew):	0	8,49	9,23	0	13,1	73,0	0	0	0	
Max:	0	15,2	11,3	0	20,1	116	0	0	0	-	
Min:	0	2,77	6,06	0	10,6	30,4	0	0	0	-	
StdevP (vb):	0	5,60	2,17	0	4,40	36,7	0	0	0	-	
Percentiel (95%)	0,10	14,1	11,1	1,00	19,2	110	0,05	1,00	50,0	-	
Weegfact.deb	40.857	40.857	40.857	40.857	40.857	40.857	40.857	40.857	40.857	-	
Aantal:	3	3	3	3	3	3	3	3	3	-	

WS Vechtstromen

Hengelo

van: naar: product:	Hengelo								Hengelo																	
	Transporteren								Afvoeren																	
	Ontvangen								Berflobeek																	
	Influent								Effluent																	
	CZV	BZV5	NKj	Ntot	Ptot	OB	TZV	Q	CZV	BZV5	NKj	NKj	NH4	NO2	NO3	NOx	Ntot	PO4	PO4	Ptot	Ptot	OB	Cl	SO4	TZV	Q
	O2	O2	N	N	P	NVT	O2	NVT	O2	O2	N	Nnf	Nnf	N	N	N	N	N	P	Pnf	P	Pnf	NVT	nf	NVT	O2
	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	m3 (bem)	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	m3 (bem)
Gem(rek):*	519	177	55,0	54,9	9,03	239	767	49.342	58,3	2,75	4,47	3,98	1,17	0,27	5,00	5,28	9,75	0,29	0,31	0,64	0,36	4,64	265	80,5	78,8	48.165
Gem (gew):	453	153	42,0	45,1	7,17	213	664		52,5	3,04	4,43	3,82	1,38	0,29	4,58	4,87	9,30	0,33	0,27	0,64	0,38	5,36	263	46,3	72,5	
Max:	882	311	86,7	86,7	19,7	436	1.250	194.323	86,0	7,00	9,70	8,60	5,50	1,10	9,00	9,40	15,7	2,20	2,30	2,80	2,50	16,0	290	88,0	127	194.323
Min:	148	46,0	12,1	12,3	1,42	51,8	209	22.920	25,0	0,98	1,40	0,44	0,10	0,02	2,10	2,60	4,40	0,02	0,02	0,23	0,03	2,04	240	73,0	31,4	22.920
StdevP:	170	63,0	19,9	19,8	4,63	85,0	242	33.960	15,9	1,27	1,39	1,54	1,09	0,26	1,41	1,44	2,41	0,41	0,41	0,45	0,47	3,01	25,0	7,50	20,2	32.093
Percentiel (95%)	774	292	84,0	83,9	16,4	367	1.148	104.195	80,7	5,00	6,57	6,43	2,90	0,75	7,75	7,96	13,8	0,73	1,10	1,58	0,84	8,89	288	87,3	102	105.509
Aantal:	25	25	64	65	64	25	25	65	63	63	63	56	62	63	63	63	63	29	61	63	28	63	2	2	63	65

Hengelo

porteren oppervlakte
nt